## DIRECTIONS

SHAKE WELL BEFORE USING

## FOR STEAM HEATING SYSTEMS

- Pour the proper amount of UTILITY BOILER COLLOID (as specified below) through the safety valve or any other convenient opening in the boiler.
- UTILITY BOILER COLLOID should be allowed to remain in normally operating boiler for 2 weeks. When dirt, rust, scale, oil or grease are present in excessive quantities, results will be apparent within 24 hours after introduction of UTILITY BOILER COLLOID, indicated by turbulence of the water. In such cases, proceed immediately to step 3.
- Drain boiler WITHOUT PRESSURE, flushing it thoroughly with hose. At this time, add a new application of **UTILITY BOILER COLLOID** and allow it to remain in the boiler to prevent any further rust and corrosion. NO DRAINING OR FLUSHING is necessary.
- 4. Application of UTILITY BOILER COLLOID should be followed by UTILITY ©. ©. RUST-X.

## FOR HOT WATER HEATING SYSTEMS

Follow directions above, but do not use in systems containing anti-freeze.

## **AMOUNT REQUIRED**

Use one (1) quart of **UTILITY BOILER COLLOID** for every 20 gallons of water in system. If capacity is unknown, use one (1) quart for every 500 sq. ft. of radiation rating of boiler or for every 120,000 B.T.U. Use this amount for cleaning and the same amount for treatment.

**CAUTION:** AVOID CONTACT WITH SKIN OR EYES. HARMFUL IF SWALLOWED. Eye and skin irritant. If ingested, do not induce vomiting. Drink plenty of water or milk. Call a physician. For eyes, flush with plenty of water while holding eyelids apart. Call a physician. Wash contaminated area with plenty of soap and water.

KEEP OUT OF REACH OF CHILDREN

Contains: Silicic acid, sodium salt (C.A.S. #1344-09-8)





