

RIBM2402SB

LED ON = RELAY ACTIVATED

Bulletin B519 • 393012B



TYPE F, G, EM
For use with
Smoke Control System
General Signaling
Equip. NM

Functional Devices, Inc.
310 South Union Street
Russiaville, IN 46979
Phone: (765)883-5538
Fax: (765)883-7505

COIL RATINGS

INPUT ISOLATED FROM OUTPUT

47 mA @ 30 Vdc

83 mA @ 24 Vac

69 mA @ 208-277 Vac

COIL

Comm

24Vac/dc

208-277Vac

**Functional
Devices, Inc.**



www.functionaldevices.com

N/O **N/C** Connect Yellow Jumper Wire
 to N/O or N/C



CONTACT RATINGS

20A Resistive @ 277 Vac

1 HP @ 120 Vac

2 HP @ 277 Vac

20 A Ballast N/O @ 277 Vac

10 A Ballast N/C @ 277 Vac

10 A Tungsten N/O @ 120 Vac

770 VA Pilot @ 120 Vac

1110 VA Pilot @ 277 Vac

CONTACTS

Relay Contacts

Not Used